



Product Service

# Attestation of Compliance

No. E8N 13 12 86747 002

**Holder of Certificate:** **ENERGON - HELLAS**  
**G.N. KYTINOS & SIA O.E.**  
 Arethousis 44  
 34100 Halkida  
 GREECE

**Name of Object:** **Heat pump**  
**(Inverter air source heat pump)**

**Model(s):** **AXAI-15**

**Description of Object:**

Rated voltage:	220-240Vac	
Rated frequency:	50Hz	
Rated power input:	Cooling	Heating
Indoor unit	54W/0.4A	54W (+4000W**)/ 0.4A (+17.4A**)
Outdoor unit	4800W/20.4A	4400W/19.0A
Protection class:	I	
Remark:**	Related to the supplementary heater	

**Tested according to:**

- EN 55014-1/A2:2011
- EN 55014-2/A2:2008
- EN 61000-3-11:2000
- EN 61000-3-12:2011

This Attestation of Compliance is issued according to the Directive 2004/108/EC relating to electromagnetic compatibility on a voluntary basis. It confirms that the listed apparatus complies with all essential requirements of the EMC directive and applies only to the sample and its technical documentation submitted to TÜV SÜD Product Service GmbH for testing and certification. See also notes overleaf.

**Test report no.:** 64711120320601B



**Date,** 2013-12-13 (Tony Liu)

**CE** After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.