



Product Service

# Attestation of Conformity

No. N8 13 12 86747 001

**Holder of Certificate:** **ENERGON - HELLAS**  
**G.N. KYTINOS & SIA O.E.**

Arethousis 44  
34100 Halkida  
GREECE

**Product:** **Heat pump**  
**(Inverter air source heat pump)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:** 64111130353101



**Date,** 2013-12-11

  
( Gary Sun )

**CE** After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2



Product Service

**Attestation of Conformity**

**No. N8 13 12 86747 001**

**Model(s): AXAI-15**

**Trade name: ENERAGON-HELLAS**

**Parameters:**

Rated Voltage:	220-240V~	
Rated Frequency:	50Hz	
Rated Power/Current:	Cooling Heating	
Indoor unit	54W/0.4A	54W (+4000W**)/ 0.4A (+17.4A**)
Outdoor unit	4800W/20.4A	4400W/19.0A
Protection Class:	Class I	
Degree of Protection:	IPX1(indoor unit) IPX4(outdoor unit)	
Refrigerant:	R410A	
Remark:	** Related to the supplementary heater.	

**Tested according to:**

EN 60335-2-40/A13:2012  
 EN 60335-2-35/A2:2011  
 EN 60335-1:2012  
 EN 62233:2008